



507 – GUARD POSTS STANDARD

The information contained in this standard is provided solely for the convenience of the reader and was being enforced by the Ventura County Fire Protection District at the time of its publication. The District reserves the right to make changes and improvements to this standard as and when required by law, or otherwise, at any time. The District's current standards will be posted and made available for downloading by the public at the following web site: www.vcfd.org.

Please note that the District assumes no liability for any damages incurred directly or indirectly as a result of any errors, omissions, or discrepancies between this standard and any applicable law. It is the sole responsibility of the person or persons conducting any work pursuant to this standard to ensure their work complies with any and all applicable codes, ordinances, and regulations.

Supersedes: VCFPD Standard 14.4.2

CHAPTER 1 – ADMINISTRATION

1.1 Purpose. This standard is prepared for the use and guidance of those installing guard posts.

1.2 Scope. This standard provides the minimum design and installation requirements for guard posts providing vehicular impact protection for above-ground tanks, hazardous materials containers, storage areas, piping, conduit, valves, fittings, dispensing areas, utility equipment and fire protection equipment; including fire hydrants, fire department connections (FDC's), and other similar equipment.

1.3 Applicability. This standard shall apply to all guard posts installed within the jurisdictional boundaries of the Ventura County Fire Protection District.

1.4 Permits. No additional permits or plans are required for the installation of guard posts. Contact the local Building and Safety and/or Planning Departments for additional information regarding possible permits required by these agencies.

CHAPTER 2 – DEFINITIONS

Guard Post. A tubular steel post filled with concrete design and installed to provide protection from vehicular damage.

CHAPTER 3 – GENERAL REQUIREMENTS

3.1 General. Vehicle impact protection required by the current adopted edition of the Ventura County Fire Code (VCFC) shall be comply with this standard.

3.2 Material. Guard posts shall be constructed of Schedule 40 steel a minimum of 4-inches in diameter and concrete filled. Where heavy equipment is present, the minimum diameter shall be 6-inches.

3.3 Depth of Bury. Guard posts shall be set a minimum of 3-feet deep in a concrete footing. When using a 4-inch diameter post, the footing shall be a minimum of 15-inches in diameter. The footing shall have a minimum diameter of 20-inches when using a 6-inch diameter post. The footing shall be a minimum of 4-feet deep.

3.4 Height. Guard posts shall be set with the top of the posts a minimum of 3-feet above the finished grade level. Where implements can over swing the guard post, the minimum height shall be to the top of the tank or equipment being protected or as approved by the fire code official.

3.5 Spacing. Guard posts shall be spaced a maximum of 4-feet on center between posts.

3.6 Location. Guard posts shall be located a minimum of 3-feet from the item being protected.

3.7 Color. Guard posts shall be painted a high-visibility color that contrasts to the surrounding environment.

3.8 Obstructions. Guard posts shall not cause an obstruction to the use, service or maintenance of any fire protection equipment.

EXHIBIT A

